

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 23, 2021

Sample ID: 21063A

Date Analyzed: 7/21/21 – 7/22/21

WO Number: 21062325063A

Customer: Mayfield Central School District

Collection Date: 6/23/21 & 6/25/21

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Mayfield Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
89	5-6 Drinking fountain	8:05 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
58	5-6 Drinking fountain bottle fill	8:06 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
26	1-2 Men's - Office	6:03 AM	6/25/21	4.9	15.0		EPA 200.8 REV 5.4
113	1-2 Women's	6:02 AM	6/25/21	1.5	15.0		EPA 200.8 REV 5.4
42	16 Fountain - Rameyn	7:58 AM	6/23/21	2.3	15.0		EPA 200.8 REV 5.4
204	16 Sink - Rameyn	5:32 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
82	17 Fountain - Horstman	8:00 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
125	17 Sink - Horstman	5:31 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
129	18 Fountain - Graf	8:04 AM	6/23/21	1.0	15.0		EPA 200.8 REV 5.4
205	18 Sink - Graf	5:30 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
128	2 Art Room	5:57 AM	6/23/21	2.2	15.0		EPA 200.8 REV 5.4
80	20 Fountain - Bumpus	8:06 AM	6/23/21	2.5	15.0		EPA 200.8 REV 5.4
86	20 Sink - Bumpus	5:28 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
12	21 Sink #1 - Bennett	8:08 AM	6/23/21	12.2	15.0		EPA 200.8 REV 5.4
206	21 Sink #2 - Bennett	5:26 AM	6/25/21	20.3	15.0	X	EPA 200.8 REV 5.4
210	22 A Bathroom	5:18 AM	6/25/21	2.5	15.0		EPA 200.8 REV 5.4
220	22 A Fountain	5:19 AM	6/25/21	1.3	15.0		EPA 200.8 REV 5.4
224	22 A Sink	5:19 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
209	22 B Bathroom	5:21 AM	6/25/21	1.8	15.0		EPA 200.8 REV 5.4
219	22 B Fountain	5:22 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
207	22 B Sink	5:23 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
218	22 Sink #1 - Horn	5:24 AM	6/25/21	19.2	15.0	X	EPA 200.8 REV 5.4
221	22 Sink #2 - Horn	5:25 AM	6/25/21	19.4	15.0	X	EPA 200.8 REV 5.4
77	23 Fountain - Conklin	8:05 AM	6/23/21	2.2	15.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 23, 2021

Sample ID: 21063A

Date Analyzed: 7/21/21 – 7/22/21

WO Number: 21062325063A

Customer: Mayfield Central School District

Collection Date: 6/23/21 & 6/25/21

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Mayfield Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
49	23 Sink - Conklin	5:35 AM	6/25/21	1.7	15.0		EPA 200.8 REV 5.4
60	24 Fountain - Codi	8:10 AM	6/23/21	2.1	15.0		EPA 200.8 REV 5.4
120	24 Sink - Codi	5:36 AM	6/25/21	1.2	15.0		EPA 200.8 REV 5.4
131	27 Fountain - Stoliker	8:02 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
222	27 Sink - Stoliker	5:37 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
57	28 Fountain - McKeough	8:00 AM	6/23/21	1.1	15.0		EPA 200.8 REV 5.4
14	28 Sink - McKeough	5:38 AM	6/25/21	1.2	15.0		EPA 200.8 REV 5.4
11	3 Principals Bathroom	8:37 AM	6/23/21	4.0	15.0		EPA 200.8 REV 5.4
xxxx	31 Sink - Custodian Office - Not Sampled - Slop Sink	xxxx	xxxx		15.0		EPA 200.8 REV 5.4
97	3-4 Drinking fountain	6:44 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
51	41 Fountain - Winters	5:35 AM	6/23/21	1.4	15.0		EPA 200.8 REV 5.4
115	41 Sink	5:36 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
208	41 Sink - Winters	5:42 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
59	43 Staff Room Fountain	5:47 AM	6/23/21	9.2	15.0		EPA 200.8 REV 5.4
3	43 Staff Room Sink	5:43 AM	6/25/21	2.1	15.0		EPA 200.8 REV 5.4
104	44 - Art Room - sink #1	5:56 AM	6/23/21	2.5	15.0		EPA 200.8 REV 5.4
63	45 Fountain - Bornt	6:00 AM	6/23/21	7.0	15.0		EPA 200.8 REV 5.4
100	45 Sink - Bornt	5:45 AM	6/25/21	1.8	15.0		EPA 200.8 REV 5.4
35	46 Fountain - Jordan	6:07 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
1	46 Sink - Jordan	5:56 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
73	47 Fountain - Luck	6:03 AM	6/23/21	4.4	15.0		EPA 200.8 REV 5.4
85	47 Sink - Luck	5:47 AM	6/25/21	2.2	15.0		EPA 200.8 REV 5.4
112	48 Fountain - Mellen	6:12 AM	6/23/21	2.2	15.0		EPA 200.8 REV 5.4
87	48 Sink - Mellen	5:58 AM	6/25/21	1.1	15.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 23, 2021

Sample ID: 21063A

Date Analyzed: 7/21/21 – 7/22/21

WO Number: 21062325063A

Customer: Mayfield Central School District

Collection Date: 6/23/21 & 6/25/21

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Mayfield Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
96	49 Fountain - CSE/Lambert	6:05 AM	6/23/21	1.8	15.0		EPA 200.8 REV 5.4
66	49 Sink - CSE/Lambert	6:00 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
7	5 Nurse Back Sink	5:23 AM	6/23/21	3.3	15.0		EPA 200.8 REV 5.4
23	5 Nurse Bathroom	5:24 AM	6/23/21	2.5	15.0		EPA 200.8 REV 5.4
92	5 Nurse Sink	5:24 AM	6/23/21	3.2	15.0		EPA 200.8 REV 5.4
54	50 Fountain - Klena	6:10 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
133	50 Sink - Klena	6:01 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
21	51 Women's Bathroom - Gym Corridor	6:16 AM	6/23/21	2.6	15.0		EPA 200.8 REV 5.4
103	52 Men's Bathroom - Gym Corridor	6:17 AM	6/23/21	3.3	15.0		EPA 200.8 REV 5.4
2	53 Girls Licker Room	6:20 AM	6/23/21	1.5	15.0		EPA 200.8 REV 5.4
109	59 Library office	6:46 AM	6/23/21	2.0	15.0		EPA 200.8 REV 5.4
19	64 Aides Sink	7:44 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
6	64 Fountain - Aides Room	6:28 AM	6/23/21	1.2	15.0		EPA 200.8 REV 5.4
36	64 Sink - Aides Room	6:04 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
44	66 Fountain - McGrath	6:30 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
39	67 Fountain - Liporace/Berlin	6:31 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
67	67 Sink - Liporace/Berlin	6:06 AM	6/25/21	1.0	15.0		EPA 200.8 REV 5.4
93	68 Fountain - Allen	6:32 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
119	68 Sink - Allen	6:07 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
8	69 Fountain - Douglass	6:33 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
90	69 Sink - Douglass	6:09 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
4	70 Fountain - Pawlik	6:34 AM	6/23/21	1.3	15.0		EPA 200.8 REV 5.4
47	70 Sink - Pawlik	6:10 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
110	71 Fountain - Swart	6:35 AM	6/23/21	1.0	15.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 23, 2021

Sample ID: 21063A

Date Analyzed: 7/21/21 – 7/22/21

WO Number: 21062325063A

Customer: Mayfield Central School District

Collection Date: 6/23/21 & 6/25/21

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Mayfield Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
25	71 Sink - Swart	6:11 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
56	72 Fountain	6:38 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
101	73 Fountain James - Aid/Copier	6:39 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
31	74 Fountain - Derstine	6:41 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
30	74 Sink - Derstine	6:12 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
45	75 Fountain - Brower	6:40 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
24	75 Sink - Brower	6:13 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
121	79 Sink - Bovee	6:47 AM	6/23/21	2.3	15.0		EPA 200.8 REV 5.4
116	80 Fountain	6:56 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
74	80 Sink	6:16 AM	6/25/21	1.1	15.0		EPA 200.8 REV 5.4
106	81 Fountain	6:50 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
65	82 Fountain - Mashhadi	7:00 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
126	82 Sink - Mashhadi	6:18 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
111	83 Faucet - McMullen	6:54 AM	6/23/21	3.5	15.0		EPA 200.8 REV 5.4
52	84 Fountain - Smith	7:05 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
71	84 Sink - Smith	6:20 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
127	85 Clute -Fountain	6:58 AM	6/23/21	3.3	15.0		EPA 200.8 REV 5.4
13	85 Faucet - Clute	6:19 AM	6/25/21	1.6	15.0		EPA 200.8 REV 5.4
32	86 Fountain	7:06 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
102	86 Fountain - Wittenmeyer	7:12 AM	6/23/21	1.2	15.0		EPA 200.8 REV 5.4
18	86 Sink - ittenmeyer	6:21 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4
53	87 Fountain	7:03 AM	6/23/21	5.8	15.0		EPA 200.8 REV 5.4
55	89 Fountain - McKeough	7:08 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
91	89 Sink - McKeough	6:27 AM	6/25/21	ND	15.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 23, 2021

Sample ID: 21063A

Date Analyzed: 7/21/21 – 7/22/21

WO Number: 21062325063A

Customer: Mayfield Central School District

Collection Date: 6/23/21 & 6/25/21

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Mayfield Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
38	91 Bathroom - BOCES Nurse	7:14 AM	6/23/21	1.4	15.0		EPA 200.8 REV 5.4
99	91 Fountain - BOCES Nurse	7:17 AM	6/23/21	1.7	15.0		EPA 200.8 REV 5.4
94	92 Bathroom - Bynon	7:11 AM	6/23/21	2.5	15.0		EPA 200.8 REV 5.4
124	92 Bathroom Sink - Bynon	7:29 AM	6/23/21	1.4	15.0		EPA 200.8 REV 5.4
22	92 Sink - Bynon	7:28 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
88	93 Bathroom - Winchell	7:32 AM	6/23/21	4.3	15.0		EPA 200.8 REV 5.4
9	93 Sink - Winchell	7:24 AM	6/23/21	2.6	15.0		EPA 200.8 REV 5.4
76	94 Bathroom - Huth	7:19 AM	6/23/21	1.4	15.0		EPA 200.8 REV 5.4
98	94 Fountain - Huth	7:22 AM	6/23/21	1.6	15.0		EPA 200.8 REV 5.4
33	94 Sink - Huth	6:25 AM	6/25/21	2.1	15.0		EPA 200.8 REV 5.4
50	Boys Locker Room	6:19 AM	6/23/21	2.9	15.0		EPA 200.8 REV 5.4
130	Cafeteria Drinking Fountain	8:20 AM	6/23/21	8.9	15.0		EPA 200.8 REV 5.4
10	Faculty Sink	5:48 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
68	Faculty Women's Bathroom - sink #1	5:44 AM	6/23/21	4.7	15.0		EPA 200.8 REV 5.4
43	Faculty Women's Bathroom sink #2	5:53 AM	6/25/21	2.1	15.0		EPA 200.8 REV 5.4
xxxx	Faculty Women's Bathroom sink #3 (Out of Service)	xxxx	xxxx		15.0		EPA 200.8 REV 5.4
72	Faculty Women's Bathroom sink #4	5:51 AM	6/25/21	18.5	15.0	X	EPA 200.8 REV 5.4
15	Faculty Women's Bathroom sink #5	5:51 AM	6/25/21	3.4	15.0		EPA 200.8 REV 5.4
223	Faculty Women's Bathroom sink #6	5:50 AM	6/25/21	14.5	15.0		EPA 200.8 REV 5.4
108	Gym Drinking Fountain	6:23 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
64	Gym Drinking Fountain Bottle Fill	6:23 AM	6/23/21	ND	15.0		EPA 200.8 REV 5.4
17	Kitchen Bathroom	5:20 AM	6/23/21	2.1	15.0		EPA 200.8 REV 5.4
16	Kitchen Eye Wash	6:36 AM	6/25/21	5.9	15.0		EPA 200.8 REV 5.4
84	Kitchen Sink	5:21 AM	6/23/21	6.4	15.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 23, 2021
Sample ID: 21063A
Date Analyzed: 7/21/21 – 7/22/21
WO Number: 21062325063A

<i>Customer:</i> Mayfield Central School District	<i>Collection Date:</i> 6/23/21 & 6/25/21
<i>Address:</i> 27 School Street, Mayfield, New York 12117	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Mayfield Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i> Ambient

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

< = Less than
 > = Greater than
 ≈ = Approximately
 ND = Not Detected at reporting limit
 NP = Not Provided
 mg/l = milligrams per liter = ppm
 ppm = parts per million
 µg/l = micrograms per liter = ppb
 ppb = parts per billion
 gpg = grains per gallon
 MCL = Maximum Contaminant Level
 SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10709