

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 25, 2021

Sample ID: 21063B

Date Analyzed: 7/20/21 – 7/20/21

WO Number: 210624063B

Customer: Mayfield Central School District

Collection Date: June 24, 2021

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Jr/Sr High School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

| Sample # | Mayfield Jr/Sr High School Sample Point | Collection Time | Date | Test Result (µg/l) | MCL (µg/l) | Qualifier | Method |
|----------|--|-----------------|---------|--------------------|------------|-----------|------------------|
| 203 | Gym Lobby - Ladies Room - #1 | 5:15 AM | 6/24/21 | 3.4 | 15.0 | | EPA200.8 REV 5.4 |
| 211 | Gym Lobby - Ladies Room - #2 | 5:16 AM | 6/24/21 | 5.5 | 15.0 | | EPA200.8 REV 5.4 |
| 212 | Gym Lobby - Water Fountain | 5:18 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 213 | Gym Lobby - Bottle Fill Station - Upper Fountain | 5:20 AM | 6/24/21 | 1.1 | 15.0 | | EPA200.8 REV 5.4 |
| 216 | Gym Lobby - Bottle Fill | 5:20 AM | 6/24/21 | 1.0 | 15.0 | | EPA200.8 REV 5.4 |
| 197 | Gym Lobby - Men's Room - #1 | 5:21 AM | 6/24/21 | 3.7 | 15.0 | | EPA200.8 REV 5.4 |
| 198 | Gym Lobby - Men's Room - #2 | 5:21 AM | 6/24/21 | 15.3 | 15.0 | X | EPA200.8 REV 5.4 |
| 199 | Ladies Locker Room - #1 | 5:25 AM | 6/24/21 | 3.1 | 15.0 | | EPA200.8 REV 5.4 |
| 217 | Ladies Locker Room - #2 | 5:27 AM | 6/24/21 | 3.4 | 15.0 | | EPA200.8 REV 5.4 |
| 214 | Men's Locker Room - #1 | 5:32 AM | 6/24/21 | 4.6 | 15.0 | | EPA200.8 REV 5.4 |
| 202 | Men's Locker Room - #2 | 5:33 AM | 6/24/21 | 2.3 | 15.0 | | EPA200.8 REV 5.4 |
| 190 | Men's Coach room | 5:31 AM | 6/24/21 | 1.4 | 15.0 | | EPA200.8 REV 5.4 |
| 200 | Ladies Coach room | 5:30 AM | 6/24/21 | 3.4 | 15.0 | | EPA200.8 REV 5.4 |
| 187 | Room 112 - Concession | 5:36 AM | 6/24/21 | 2.1 | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Room 120 - Ice machine (out of service) | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| 180 | Room 123 - Men's Room | 5:41 AM | 6/24/21 | 7.1 | 15.0 | | EPA200.8 REV 5.4 |
| 196 | Room 123 - Ladies Room | 5:42 AM | 6/24/21 | 1.2 | 15.0 | | EPA200.8 REV 5.4 |
| 186 | Room 123 - Utility Sink | 5:43 AM | 6/24/21 | 1.3 | 15.0 | | EPA200.8 REV 5.4 |
| 194 | 7/8 Grade Men's Room - #1 | 5:45 AM | 6/24/21 | 3.3 | 15.0 | | EPA200.8 REV 5.4 |
| 184 | 7/8 Grade Men's Room - #2 | 5:45 AM | 6/24/21 | 1.9 | 15.0 | | EPA200.8 REV 5.4 |
| 185 | 7/8 Grade Men's Room - #3 | 5:46 AM | 6/24/21 | 1.7 | 15.0 | | EPA200.8 REV 5.4 |
| 192 | 7/8 Grade Women's Room - #1 | 5:48 AM | 6/24/21 | 11.8 | 15.0 | | EPA200.8 REV 5.4 |
| 193 | 7/8 Grade Women's Room - #2 | 5:48 AM | 6/24/21 | 2.0 | 15.0 | | EPA200.8 REV 5.4 |
| 183 | 7/8 Grade Women's Room - #3 | 5:49 AM | 6/24/21 | 3.3 | 15.0 | | EPA200.8 REV 5.4 |

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 25, 2021

Sample ID: 21063B

Date Analyzed: 7/20/21 – 7/20/21

WO Number: 210624063B

Customer: Mayfield Central School District

Collection Date: June 24, 2021

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Jr/Sr High School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

| Sample # | Mayfield Jr/Sr High School Sample Point | Collection Time | Date | Test Result (µg/l) | MCL (µg/l) | Qualifier | Method |
|----------|--|-----------------|---------|--------------------|------------|-----------|------------------|
| 189 | 133 Water Fountain #1 | 5:50 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Room 135 - Science room - not sampled - not required | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Room 252 - Science room - not sampled - not required | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| 191 | Boy's Bathroom 239 - #1 | 6:00 AM | 6/24/21 | 6.2 | 15.0 | | EPA200.8 REV 5.4 |
| 173 | Boy's Bathroom 239 - #2 | 6:00 AM | 6/24/21 | 10.0 | 15.0 | | EPA200.8 REV 5.4 |
| 195 | Water fountain #2 | 6:01 AM | 6/24/21 | 8.6 | 15.0 | | EPA200.8 REV 5.4 |
| 171 | Girl's Bathroom 236 - #1 | 6:02 AM | 6/24/21 | 3.8 | 15.0 | | EPA200.8 REV 5.4 |
| 172 | Girl's Bathroom 236 - #2 | 6:03 AM | 6/24/21 | 3.7 | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Room 234 - Art room - not required | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Room 233 - Art room - not required | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| 170 | Room 235 - #1 | 6:08 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 174 | Room 235 - #2 | 6:08 AM | 6/24/21 | 2.1 | 15.0 | | EPA200.8 REV 5.4 |
| 188 | Room 235 - #3 | 6:10 AM | 6/24/21 | 2.0 | 15.0 | | EPA200.8 REV 5.4 |
| 37 | Room 235 - #4 | 4:30 PM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 169 | Main Office - Common Sink | 6:15 AM | 6/24/21 | 2.7 | 15.0 | | EPA200.8 REV 5.4 |
| 177 | Main Office - Men's Room | 6:13 AM | 6/24/21 | 2.8 | 15.0 | | EPA200.8 REV 5.4 |
| 179 | Main Office - Women's Room | 6:14 AM | 6/24/21 | 2.7 | 15.0 | | EPA200.8 REV 5.4 |
| 182 | Kitchen Bathroom | 6:17 AM | 6/24/21 | 4.3 | 15.0 | | EPA200.8 REV 5.4 |
| 175 | Kitchen Bathroom - side #1 | 6:20 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 176 | Kitchen Bathroom - side #2 | 6:21 AM | 6/24/21 | 1.1 | 15.0 | | EPA200.8 REV 5.4 |
| 163 | Kitchen Small Wash Sink -Eye wash station | 6:18 AM | 6/24/21 | 7.3 | 15.0 | | EPA200.8 REV 5.4 |
| 181 | Kitchen Island Sink | 6:19 AM | 6/24/21 | 2.0 | 15.0 | | EPA200.8 REV 5.4 |
| 168 | Serving Line | 6:22 AM | 6/24/21 | 5.4 | 15.0 | | EPA200.8 REV 5.4 |
| 162 | Bathroom Sink 228 | 6:24 AM | 6/24/21 | 4.6 | 15.0 | | EPA200.8 REV 5.4 |

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 25, 2021

Sample ID: 21063B

Date Analyzed: 7/20/21 – 7/20/21

WO Number: 210624063B

Customer: Mayfield Central School District

Collection Date: June 24, 2021

Address: 27 School Street, Mayfield, New York 12117

Collection Time: See Chart

Sample Location: Mayfield Jr/Sr High School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

| Sample # | Mayfield Jr/Sr High School Sample Point | Collection Time | Date | Test Result (µg/l) | MCL (µg/l) | Qualifiers | Method |
|----------|--|-----------------|---------|--------------------|------------|------------|------------------|
| 165 | Nurses Office 225 - sink | 6:27 AM | 6/24/21 | 3.5 | 15.0 | | EPA200.8 REV 5.4 |
| 166 | Nurses Office bathroom | 6:26 AM | 6/24/21 | 1.4 | 15.0 | | EPA200.8 REV 5.4 |
| 157 | Faculty Lounge | 6:33 AM | 6/24/21 | 2.0 | 15.0 | | EPA200.8 REV 5.4 |
| 161 | Boy's Bathroom 222 - #1 | 6:31 AM | 6/24/21 | 5.7 | 15.0 | | EPA200.8 REV 5.4 |
| 178 | Boy's Bathroom 222 - #2 | 6:32 AM | 6/24/21 | 2.7 | 15.0 | | EPA200.8 REV 5.4 |
| 167 | Water Cooler upper - next to Rm 222 | 6:29 AM | 6/24/21 | 4.2 | 15.0 | | EPA200.8 REV 5.4 |
| 164 | Water Cooler lower - next to Rm 222 | 6:30 AM | 6/24/21 | 4.3 | 15.0 | | EPA200.8 REV 5.4 |
| 159 | Bottle fill - lower cooler - next to Rm 222 | 6:30 AM | 6/24/21 | 5.3 | 15.0 | | EPA200.8 REV 5.4 |
| 155 | Girl's Bathroom 206 - #1 | 6:35 AM | 6/24/21 | 1.6 | 15.0 | | EPA200.8 REV 5.4 |
| 156 | Girl's Bathroom 206 - #2 | 6:35 AM | 6/24/21 | 2.2 | 15.0 | | EPA200.8 REV 5.4 |
| 152 | Auditorium Men's -#1 | 6:40 AM | 6/24/21 | 10.6 | 15.0 | | EPA200.8 REV 5.4 |
| 160 | Auditorium Men's -#2 | 6:40 AM | 6/24/21 | 2.6 | 15.0 | | EPA200.8 REV 5.4 |
| 151 | Auditorium Ladies - #1 | 6:39 AM | 6/24/21 | 10.1 | 15.0 | | EPA200.8 REV 5.4 |
| 150 | Auditorium Ladies - #2 | 6:39 AM | 6/24/21 | 3.6 | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Water Fountain #3 - Out of service | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Auditorium Janitor's Closet - Slop sink - not required | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| 147 | Room 214 | 6:46 AM | 6/24/21 | 1.1 | 15.0 | | EPA200.8 REV 5.4 |
| 148 | Bathroom next to 214 | 6:48 AM | 6/24/21 | 2.3 | 15.0 | | EPA200.8 REV 5.4 |
| 154 | Room 215 - Bubblers | 6:50 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 153 | Room 215 - Sink | 6:51 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 145 | Room 217 | 6:53 AM | 6/24/21 | 2.6 | 15.0 | | EPA200.8 REV 5.4 |
| 158 | Room 200 | 6:37 AM | 6/24/21 | 4.6 | 15.0 | | EPA200.8 REV 5.4 |
| xxxx | Mr. Harper's Office - Out of order - not in service | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| 40 | 3rd Floor girl's Bathroom #1 | 7:07 AM | 6/24/21 | 2.7 | 15.0 | | EPA200.8 REV 5.4 |

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 25, 2021
 Sample ID: 21063B
 Date Analyzed: 7/20/21 – 7/20/21
 WO Number: 210624063B

Customer: Mayfield Central School District
 Address: 27 School Street, Mayfield, New York 12117
 Sample Location: Mayfield Jr/Sr High School
 Sample Point: See Chart
 Water Source: Municipal Water
 Chlorinated: Yes

Collection Date: June 24, 2021
 Collection Time: See Chart
 Collected by: Angelo E. Finateri
 Potable: Yes
 Grab/Composite: Grab
 Receipt Temp: Ambient

| Sample # | Mayfield Jr/Sr High School Sample Point | Collection Time | Date | Test Result (µg/l) | MCL (µg/l) | Qualifiers | Method |
|----------|---|-----------------|---------|--------------------|------------|------------|------------------|
| 143 | 3rd Floor girl's Bathroom #2 | 7:08 AM | 6/24/21 | 2.7 | 15.0 | | EPA200.8 REV 5.4 |
| 141 | Fountain between bathrooms on 3rd floor | 7:06 AM | 6/24/21 | 1.0 | 15.0 | | EPA200.8 REV 5.4 |
| 105 | 3rd Floor Boy's Bathroom #1 | 7:05 AM | 6/24/21 | 2.5 | 15.0 | | EPA200.8 REV 5.4 |
| 132 | 3rd Floor Boy's Bathroom #2 | 7:05 AM | 6/24/21 | 2.6 | 15.0 | | EPA200.8 REV 5.4 |
| 20 | 3rd Floor Faculty Men | 7:09 AM | 6/24/21 | 1.1 | 15.0 | | EPA200.8 REV 5.4 |
| 149 | 3rd Floor Faculty Ladies | 6:59 AM | 6/24/21 | 1.4 | 15.0 | | EPA200.8 REV 5.4 |
| 146 | 3rd Floor Bathroom end of hall | 6:57 AM | 6/24/21 | 30.4 | 15.0 | X | EPA200.8 REV 5.4 |
| 144 | Water Fountain #4 | 7:00 AM | 6/24/21 | 16.0 | 15.0 | X | EPA200.8 REV 5.4 |
| xxxx | Room 209 - Science lab - not required | xxxxx | 6/24/21 | | 15.0 | | EPA200.8 REV 5.4 |
| 142 | Library Sink | 7:02 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 201 | Boy's Locker Room Drinking Fountain #5 | 5:34 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| 215 | Girl's Locker Room Drinking Fountain #6 | 5:28 AM | 6/24/21 | ND | 15.0 | | EPA200.8 REV 5.4 |
| | | | | | | | |
| | | | | | | | |
| Total | 75 | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: July 25, 2021
Sample ID: 21063B
Date Analyzed: 7/20/21 – 7/20/21
WO Number: 210624063B

| | |
|--|---|
| <i>Customer:</i> Mayfield Central School District | <i>Collection Date:</i> June 24, 2021 |
| <i>Address:</i> 27 School Street, Mayfield, New York 12117 | <i>Collection Time:</i> See Chart |
| <i>Sample Location:</i> Mayfield Jr/Sr High School | <i>Collected by:</i> Angelo E. Finateri |
| <i>Sample Point:</i> See Chart | <i>Potable:</i> Yes |
| <i>Water Source:</i> Municipal Water | <i>Grab/Composite:</i> Grab |
| <i>Chlorinated:</i> Yes | <i>Receipt Temp:</i> Ambient |

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

| | |
|---|---|
| Qualifiers: | C+: CCV above acceptable limits |
| ND: Not Detected at the reporting limit | S: LCS Spike recovery is below acceptable Limits |
| J: Analyte detected below quantitation limit | S+: LCS Spike recovery is above acceptable Limits |
| B: Analyte detected in Blank | Z: Duplication outside acceptable limits |
| X: Exceeds maximum contamination limit | T: Tentatively Identified Compound – Estimated |
| H: Hold time exceeded | E Above quantitation range - Estimated |
| N: Matrix Spike below acceptable limits | |
| N+: Matrix Spike above acceptable limits | |
| S: LCS Spike recovery outside acceptable limits | |
| C: CCV below acceptable limits | |

Legend:

< = Less than
 > = Greater than
 ≈ = Approximately
 NP = Not Provided
 mg/l = milligrams per liter = ppm
 ppm = parts per million
 µg/l = micrograms per liter = ppb
 ppb = parts per billion
 gpg = grains per gallon
 MCL = Maximum Contaminant Level
 SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10709